



**FIRE SPRINKLER AFFIDAVIT FOR ALTERATIONS OR TENANT IMPROVEMENTS
(0-10 sprinkler heads without plans) *Over the Counter***

Project Name: _____	Occupancy: _____
Job Address: _____	Type of Construction: _____
Suite: _____	Valuation: _____
Contractor: _____	Phone: _____
Number of Proposed or Altered Heads: _____	
Type: WET Hazard: LIGHT Density: 10	

I, _____, Oregon Construction Contractors Board No. _____ certify that the following is true and reasonably defines the scope of work for this project:

- a) All work is limited to drops and armovers in a light-hazard occupancy.
- b) Positions of sprinkler heads relative to architectural features such as soffits, beams, partitions, walls, etc. complies with the current edition of NFPA 13.
- c) The proposed work does not require hydraulic calculations.
- d) Only one sprinkler head will be installed from one drop (Exception: Up to two heads from one drop may be installed when each head is in a separate fire area).
- e) The area covered per sprinkler head is limited to the spacing requirements of NFPA13.
- f) The installation shall comply with the requirements of the current adopted edition of NFPA 13.
- g) Piping shall not be concealed until hangers and bracing are inspected.
- h) Final approval shall be subject to onsite tests and inspections.

In addition, I understand the following is required:

- * A sketch attached to this document showing the area of work within the building's structure, and
- * A copy of this document shall be available for all inspections.

Signature: _____ Date: _____