



NOTES:

1. CATCH BASIN TO BE USED ONLY IN AREAS WHERE CURB INLET CONFLICTS WITH UNDERGROUND UTILITIES AND WITH THE APPROVAL OF THE CITY'S AUTHORIZED REPRESENTATIVE.
2. CONCRETE SHALL ATTAIN A MIN. COMPRESSIVE STRENGTH OF 3000 PSI. IN 28 DAYS.
3. BATTER OF 1/4" TO 1" TO FACILITATE FORM REMOVAL WILL BE ALLOWED.
4. BOTTOM OF WEEP HOLE AT BOTTOM OF BASE ROCK.
5. SEE DETAIL S-2096 FOR REBAR SPACING AND HOOK BAR DETAIL

Catch Basin (G-2)

DRAWING NUMBER: S-2095

DRAWN BY: SR

SCALE: N.T.S.

FILE NAME: S-2095.DWG

APPROVED BY: NK

DATE: 6/4/14

CITY OF  
WILSONVILLE



PUBLIC WORKS STANDARDS