



NOTES:

1. ALL PARTS SHALL BE A-304 STAINLESS STEEL.
2. UNTHREADED LENGTH VARIES AND SHALL NOT EXCEED 9 INCHES
3. 1/8" RUBBER GASKET MATERIAL TO BE PLACED ABOVE AND BELOW RESTRAINED PIPE.

Stainless Steel Pipe Support

CITY OF
WILSONVILLE



DRAWING NUMBER: WT-3095

DRAWN BY: SR

SCALE: N.T.S.

FILE NAME: WT-3095.DWG

APPROVED BY: NK

DATE: 6/4/14

PUBLIC WORKS STANDARDS