

RESOLUTION NO. 977

A RESOLUTION OF THE CITY OF WILSONVILLE AMENDING ORDINANCE 92-01 OF THE TUALATIN VALLEY FIRE AND RESCUE, A RURAL FIRE PROTECTION DISTRICT.

WHEREAS, the City Council of the City of Wilsonville has received and reviewed the proposed Fire Code, Ordinance 92-01 of Tualatin Valley Fire and Rescue, a Rural Fire Protection District; and

WHEREAS, the City Council believes there is a need to update the fire codes, and to proscribe regulations governing conditions hazardous to life and property from fire and explosion; and

WHEREAS, certain provisions of Ordinance 92-01 of Tualatin Valley Fire and Rescue, a Rural Fire Protection District, are identical to provisions of the City's Building Code, thereby requiring uniform and consistent interpretations; and

WHEREAS, it is the desire of the Building Official to amend Ordinance 92-01 to include a provision to require that new commercial development be provided with not less than 1500 gallons per minute of fire flow.

NOW, THEREFORE, THE CITY OF WILSONVILLE RESOLVES AS FOLLOWS:

Section 1 That the Tualatin Valley Fire and Rescue, a Rural Fire Protection District, Ordinance 92-01 is hereby approved, as amended, as required by ORS 478.924.

Section 2 That in the event that identical provisions are in the City's Building Code and Ordinance 92-01 which require interpretation, the determination of the City Building Code will be final and binding.

Section 3 That Ordinance 92-01 of the Tualatin Valley Fire and Rescue, a Rural Fire Protection District, is hereby amended to require new commercial development be provided with not less than 1500 gallons per minute of fire flow.

ADOPTED by the Wilsonville City Council at a regular meeting thereof this 16th day of February, 1993 and filed with the City Recorder this date.



GERALD A. KRUMMEL, Mayor

ATTEST:



VERA A. ROJAS, CMC/AAE, City Recorder

SUMMARY of Votes:

Mayor Krummel AYE

Councilor Carter AYE

Councilor Hawkins AYE

Councilor Lehan AYE

Councilor Van Eck AYE